

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Total Trihalomethane MCL Violation at Cameron Trading Post

Our water system recently violated a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what has happened and what we have done and continue to do to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results from 08/01/17 show that our system exceeds the standard or maximum contaminant level (MCL), for Trihalomethane (TTHM). The standard for TTHM is 0.080. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of TTHM averaged at one of our system's locations for the last 4 testing periods was 0.125.

What should I do?

- There is nothing you need to do unless you have a severely compromised immune system, have an infant, or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.
- You do not need to boil your water or take other corrective actions. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours. We will announce any emergencies on KTNN AM 660.

What does this mean?

This is not an emergency. If it had been an emergency, you would have been notified within 24 hours.

People who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What is being done?

Previous measures to reduce TTHM have been ineffective. Cameron Trading Post has contracted Arizona Department of Environmental Quality recommended engineering firm who will determine the case and help implement the solution by February 2018.

For more information, please contact Josh Atkinson at 928-679-2231 or PO Box 339, Cameron, AZ 86020.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Cameron Trading Post. State Water System ID#:03-006
Date distributed: 10-24-17