

RECEIVED APR 21 2017

ENTERED APR 21 2017

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Total Trihalomethanes (TTHM) MCL Violation at Moovalya Keys

The Moovalya Keys water system recently violated a drinking water standard. Although this incident was **NOT AN EMERGENCY**, as our customers, you have a right to know what happened and what is being done to correct this situation.

We routinely monitor for the presence of dozens of drinking water contaminants. Testing results from January 2017 show that our system exceeded the standard or maximum contaminant level (MCL), for TTHM. The standard for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the past four quarters. The level of TTHM averaged on one of the dual samples taken at one of the Moovalya Keys water system sample locations for April 2016 through January 2017 was 0.0832 mg/L. **THIS EXCEEDANCE IS NOT AN EMERGENCY!**

What should I do?

- There **is nothing you need to do** unless you have a severely compromised immune system, have an infant, or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers. According to the Company's records we believe this is the first occasion of TTHM exceedance in the Moovalya Keys system.
- You **do not need to boil your water or take other corrective actions**. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours. We will publicly announce any emergencies on local radio or television stations, if applicable.

What does this mean?

THIS IS NOT AN EMERGENCY!!! If it had been an emergency, you would have been notified within 24 hours. People who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

What is being done?

It is important to understand that many locations in the water system are regularly sampled. Dual samples are taken at all locations. The current results reflect that only one of the dual samples taken at only one location caused the above explained exceedance. Nonetheless, the very small MCL exceedance is required to be noticed under the Rules.

For more information, please contact the Customer Service Center at (800) 270-6084 for further information. Please share this information with other people who drink this water from your location, especially those who may not have received this notice directly.

This notice is being sent to you during the month of April 2017 by Brooke Water LLC, Arizona Public Water System number 15-006.