

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Rio Verde RV Park Has Levels of Arsenic above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample tested on 12/9/16 show that our system exceeds the standard or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb). The average level of arsenic from March 2016 to December 2016 has been 40 ppb.

What should I do?

If you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

What is being done?

For more information, please contact the office at 634-5990.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Rio Verde RV Park. State Water System ID#: 13-425.
Date distributed: January 24, 2017.