

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

SIERRA PACIFIC MOBILE HOME PARK Has Levels of Arsenic Above Drinking Water Standards

Our water system, **SIERRA PACIFIC MHP**, on 7/18/17, violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received on August 28 2017 show that our system exceeds the standard or maximum contaminant level (MCL), for arsenic. The standard for arsenic is .01 milligrams per liter. The average level of arsenic was .018 mgL.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

What is being done?

We are monitoring.

For more information, please contact Sierra Pacific MHP at 928.344.1606

This notice is being sent to you by Sierra Pacific. Public Water System ID#: AZ-04-14 098 Date distributed: August 8 2017.

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica"