

## 2021 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level	Other Combined PFAs
1/27/2021	4AL Raw	0.035	0.017	0.052	0.070 (Combined)	0.0461
	4AL Post Lead	0.023	0.020	0.043	0.070 (Combined)	0.0566
	4AL Post Lag (finished water)	0.0045	0.012	0.017	0.070 (Combined)	0.0448
	10AL Raw	0.052	0.018	0.070	0.070 (Combined)	0.0661
	10AL Post Lead	ND	ND	ND	0.070 (Combined)	0.0031
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
1/27/2021	5AL Raw	0.0065	0.0074	0.0139	0.070 (Combined)	0.0202
	6AL Raw	0.0037	0.0045	0.0082	0.070 (Combined)	0.0123
	ALR	0.0049	0.0076	0.0125	0.070 (Combined)	0.0237
2/24/2021	4AL Post Lag	ND	ND	ND	0.070 (Combined)	0.0853
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
2/24/2021	TW4	ND	0.0054	0.0054	0.070 (Combined)	0.0127
	TW5	ND	0.0058	0.0058	0.070 (Combined)	0.0160
2/26/2021	ALR	0.0075	0.0098	0.0173	0.070 (Combined)	0.0283
	TWR	0.0021	0.0043	0.0064	0.070 (Combined)	0.0123

## 2020 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level	Other Combined PFAs
Jan-20	All GAC wells are off					
2/12/2020	2AL Post Lead	0.023	0.020	0.043	0.070 (Combined)	0.101
	2AL Post Lag (finished water)	ND	0.0039	0.0039	0.070 (Combined)	0.0481
	4AL Post Lead	0.0036	0.0086	0.0122	0.070 (Combined)	0.0338
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0135
Mar-20	All GAC wells are off - all GAC wells had media changeout in March					
4/23/2020	2AL Post Lead	ND	ND	ND	0.070 (Combined)	ND
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	4AL Post Lead	ND	ND	ND	0.070 (Combined)	ND
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
5/22/2020	2AL Raw	0.16	0.044	0.204	0.070 (Combined)	0.1521
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	4AL Raw	0.03	0.017	0.047	0.070 (Combined)	0.0426
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	10AL Raw	0.043	0.018	0.061	0.070 (Combined)	0.0602
	10AL Post Lead	ND	ND	ND	0.070 (Combined)	ND
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
5/22/2020	5AL Raw	0.0053	0.0068	0.0121	0.070 (Combined)	0.0176
	6AL Raw	0.0032	0.0037	0.0069	0.070 (Combined)	0.0085
	9AL Raw	0.021	0.015	0.036	0.070 (Combined)	0.0353
	TW1 Raw	ND	ND	ND	0.070 (Combined)	0.0032
	TW2 Raw	0.0024	ND	0.0024	0.070 (Combined)	0.0057
	TW4 Raw	ND	0.005	0.005	0.070 (Combined)	0.0114
	TW5 Raw	ND	0.0056	0.0056	0.070 (Combined)	0.0120
	TW6 Raw	ND	0.0048	0.0048	0.070 (Combined)	0.0024
	34C Raw	0.0026	0.0021	0.0047	0.070 (Combined)	0.0041
6/23/2020	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
6/23/2020	20B Raw	ND	ND	ND	0.070 (Combined)	ND
7/22/2020	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0022
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
8/19/2020	2AL Raw	0.15	0.037	0.187	0.070 (Combined)	0.1408
	2AL Post Lead	0.015	0.011	0.026	0.070 (Combined)	0.0589
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0072
	4AL Raw	0.028	0.016	0.044	0.070 (Combined)	0.0409
	4AL Post Lead	0.0022	0.005	0.007	0.070 (Combined)	0.0264
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0094
	10AL Raw	0.044	0.018	0.062	0.070 (Combined)	0.0643
	10AL Post Lead	ND	ND	ND	0.070 (Combined)	ND
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
8/19/2020	5AL Raw	0.0051	0.0062	0.011	0.070 (Combined)	0.0174
	6AL Raw	0.0031	0.0034	0.007	0.070 (Combined)	0.0082
	9AL Raw	0.02	0.014	0.034	0.070 (Combined)	0.0341
	TW1 Raw	ND	ND	ND	0.070 (Combined)	0.0032
	TW2 Raw	0.0026	ND	0.002	0.070 (Combined)	0.0060
	TW4 Raw	ND	0.0049	0.0049	0.070 (Combined)	0.0120
	TW5 Raw	ND	0.0043	0.0043	0.070 (Combined)	0.0125
	TW6 Raw	ND	0.0042	0.0042	0.070 (Combined)	0.0026
	34C Raw	0.0025	ND	0.0025	0.070 (Combined)	0.0060
9/23/2020	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0253
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	0.0168
10/27/2020	2AL Post Lag (finished water)	0.0024	0.0044	0.0068	0.070 (Combined)	0.0514
	4AL Post Lag (finished water)	ND	0.0029	0.0029	0.070 (Combined)	0.0249
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
11/30/2020	4AL Raw	0.035	0.017	0.052	0.070 (Combined)	0.0467
	4AL Post Lead	0.013	0.015	0.028	0.070 (Combined)	0.0507
	4AL Post Lag (finished water)	ND	0.0058	0.0058	0.070 (Combined)	0.0359
	10AL Raw	0.052	0.02	0.072	0.070 (Combined)	0.0714
	10AL Post Lead	ND	ND	ND	0.070 (Combined)	ND
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
11/30/2020	5AL Raw	0.0056	0.0069	0.0125	0.070 (Combined)	0.0187
	6AL Raw	0.0036	0.0042	0.0078	0.070 (Combined)	0.0117
	9AL Raw	Off				
	TW1 Raw	ND	ND	ND	0.070 (Combined)	0.0039
	TW2 Raw	0.0030	0.0022	0.0052	0.070 (Combined)	0.0090
	TW4 Raw	ND	0.0055	0.0055	0.070 (Combined)	0.0146
	TW5 Raw	ND	0.0057	0.0057	0.070 (Combined)	0.0174
	TW6 Raw	ND	0.0046	0.0046	0.070 (Combined)	0.0031
	34C Raw	0.0031	0.0020	0.0051	0.070 (Combined)	0.0093
	20B Raw	ND	ND	ND	0.070 (Combined)	ND
12/21/2020	4AL Post Lag (finished water)	0.0023	0.0080	0.0103	0.070 (Combined)	0.0401

## 2019 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level
1/25/2019	10AL Post Lead	ND	ND	ND	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
2/22/2019	10AL Post Lead	ND	ND	ND	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
3/13/2019	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
3/20/2019	10AL Post Lead	ND	ND	ND	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
4/22/2019	2AL - Raw	0.16	0.04	0.200	0.070 (Combined)
	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
4/22/2019	10AL - Raw	0.025	0.020	0.045	0.070 (Combined)
	10AL - Post Lead	ND	0.002	0.002	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
5/22/2019	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
5/22/2019	10AL - Post Lead	ND	0.0057	0.0057	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
6/20/2019	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
6/20/2019	10AL - Post Lead	ND	0.007	0.007	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
7/24/2019	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
7/24/2019	4AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
7/24/2019	10AL - Post Lead	ND	0.0130	0.0130	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
8/22/2019	2AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
8/22/2019	4AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
	10AL - Post Lead	ND	0.0130	0.0130	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
9/24/2019	4AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
10/23/2019	2AL - Raw	0.12	0.038	0.158	0.070 (Combined)
	2AL - Post Lead	0.011	0.012	0.023	0.070 (Combined)
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
10/23/2019	4AL - Raw	0.019	0.014	0.033	0.070 (Combined)
	4AL - Post Lead	ND	ND	ND	0.070 (Combined)
	4AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
10/23/2019	10AL - Raw	0.039	0.018	0.057	0.070 (Combined)
	10AL - Post Lead	0.0036	0.018	0.0216	0.070 (Combined)
	10AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)
11/19/2019	4AL - Post Lag Filter (finished water)	ND	ND	ND	0.070 (Combined)
Dec-2019	All GAC Wells are off				

2018 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level
1/25/2018	2AL - Raw	0.15	0.033	0.183	0.070 (Combined)
1/25/2018	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
1/25/2018	2AL - Post Lag Filter (finished wate	ND	0.003	0.003	0.070 (Combined)
1/25/2018	4AL - Raw	0.033	0.015	0.048	0.070 (Combined)
1/25/2018	4AL - Post Lead Filter	0.014	0.012	0.026	0.070 (Combined)
1/25/2018	4AL - Post Lag Filter (finished wate	ND	0.005	0.005	0.070 (Combined)
1/25/2018	9AL	0.015	0.011	0.026	0.070 (Combined)
1/25/2018	TW2	ND	ND	ND	0.070 (Combined)
1/25/2018	TW5	ND	0.0031	0.0031	0.070 (Combined)
1/25/2018	EPDS 001 (TWR)	ND	0.0026	0.0026	0.070 (Combined)
1/25/2018	EPDS 003 (ALR)	0.011	0.0099	0.0209	0.070 (Combined)
1/25/2018	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
2/23/2018	2AL - Raw	0.15	0.035	0.185	0.070 (Combined)
2/23/2018	2AL - Post Lead Filter	ND	0.0058	0.0058	0.070 (Combined)
2/23/2018	2AL - Post Lag Filter (finished wate	ND	0.006	0.0086	0.070 (Combined)
2/23/2018	4AL - Raw	0.033	0.017	0.05	0.070 (Combined)
2/23/2018	4AL - Post Lead Filter	0.018	0.016	0.034	0.070 (Combined)
2/23/2018	4AL - Post Lag Filter (finished wate	0.0031	0.0085	0.0116	0.070 (Combined)
2/23/2018	9AL	0.022	0.013	0.035	0.070 (Combined)
2/23/2018	TW2	ND	ND	ND	0.070 (Combined)
2/23/2018	EPDS 001 (TWR)	ND	ND	ND	0.070 (Combined)
2/23/2018	EPDS 003 (ALR)	0.016	0.012	0.028	0.070 (Combined)
2/23/2018	EPDS 005 (10AL)	0.034	0.022	0.056	0.070 (Combined)
2/23/2018	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
3/7/2018	Marbella Well	0.0032	ND	0.0032	0.070 (Combined)
3/23/2018	2AL - Raw	0.14	0.033	0.173	0.070 (Combined)
3/23/2018	2AL - Post Lead Filter - Bottom	ND	ND	0.0089	0.070 (Combined)
3/23/2018	2AL - Post Lag Filter - Middle	ND	0.006	0.0047	0.070 (Combined)
3/23/2018	4AL - Raw	0.03	0.016	0.046	0.070 (Combined)
3/23/2018	4AL - Post Lead Filter	0.016	0.014	0.03	0.070 (Combined)
3/23/2018	4AL - Post Lag Filter (finished wate	0.0048	0.01	0.0148	0.070 (Combined)
3/23/2018	SAL	0.0031	0.0045	0.0076	0.070 (Combined)
3/23/2018	TW2	ND	ND	ND	0.070 (Combined)
3/23/2018	TW5	ND	0.0037	0.0037	0.070 (Combined)
3/23/2018	EPDS 001 (TWR)	ND	0.0032	0.0032	0.070 (Combined)
3/23/2018	EPDS 003 (ALR)	0.0046	0.0078	0.0124	0.070 (Combined)
3/23/2018	EPDS 005 (10AL)	0.051	0.021	0.052	0.070 (Combined)
4/10/2018	10AL - Raw	0.031	0.020	0.051	0.070 (Combined)
4/10/2018	10AL - Post Lag Filter (finished wat	ND	ND	ND	0.070 (Combined)
4/17/2018	2AL - Raw	0.13	0.033	0.163	0.070 (Combined)
4/17/2018	2AL - Post Lead Filter - Top	0.1	0.036	0.136	0.070 (Combined)
4/17/2018	2AL - Post Lead Filter - Bottom	0.046	0.021	0.067	0.070 (Combined)
4/17/2018	2AL - Post Lag Filter - Top	0.024	0.019	0.043	0.070 (Combined)
4/17/2018	2AL - Post Lag Filter - Bottom	0.005	0.008	0.013	0.070 (Combined)
4/17/2018	4AL - Raw	0.031	0.015	0.046	0.070 (Combined)
4/17/2018	4AL - Post Lead Filter	0.02	0.016	0.036	0.070 (Combined)
4/17/2018	4AL - Post Lag Filter (finished wate	0.0058	0.012	0.0178	0.070 (Combined)
4/17/2018	10AL - Raw	0.031	0.020	0.051	0.070 (Combined)
4/17/2018	10AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
4/17/2018	10AL - Post Lag Filter (finished wat	ND	ND	ND	0.070 (Combined)
4/17/2018	SAL	ND	0.0034	0.0034	0.070 (Combined)
4/17/2018	9AL	0.02	0.012	0.032	0.070 (Combined)
4/17/2018	TW2	ND	ND	ND	0.070 (Combined)
4/17/2018	TW4	ND	0.0038	0.0038	0.070 (Combined)
4/17/2018	TW5	ND	0.0037	0.0037	0.070 (Combined)
4/17/2018	EPDS 001 (TWR)	ND	0.0037	0.0037	0.070 (Combined)
4/17/2018	EPDS 003 (ALR)	0.0092	0.0087	0.0179	0.070 (Combined)
4/17/2018	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
5/7/2018	Marbella Well	ND	ND	ND	0.070 (Combined)
5/7/2018	10AL - Raw	0.031	0.019	0.050	0.070 (Combined)
5/7/2018	10AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
5/7/2018	10AL - Post Lag Filter (finished wat	ND	ND	ND	0.070 (Combined)
5/9/2018	2AL - Raw	0.13	0.033	0.163	0.070 (Combined)
5/9/2018	2AL - Post Lag Filter - Bottom	0.0067	0.0099	0.0166	0.070 (Combined)
5/18/2018	SAL	0.0026	0.0036	0.0062	0.070 (Combined)
5/18/2018	9AL	0.021	0.015	0.036	0.070 (Combined)
5/18/2018	TW1	ND	ND	ND	0.070 (Combined)
5/18/2018	TW2	ND	ND	ND	0.070 (Combined)
5/18/2018	TW4	ND	0.0046	0.0046	0.070 (Combined)
5/18/2018	TW5	ND	0.0039	0.0039	0.070 (Combined)
5/18/2018	EPDS 001 (TWR)	ND	0.0032	0.0032	0.070 (Combined)
5/18/2018	EPDS 002 (20B ATF)	0.0063	0.0048	0.0111	0.070 (Combined)
5/18/2018	EPDS 003 (ALR)	0.011	0.01	0.021	0.070 (Combined)
5/18/2018	EPDS 006 (34C)	0.0026	ND	0.0026	0.070 (Combined)
5/18/2018	2AL - Raw	0.16	0.037	0.197	0.070 (Combined)
5/18/2018	2AL - Post Lead Filter - Top	0.14	0.044	0.184	0.070 (Combined)
5/18/2018	2AL - Post Lead Filter - Bottom	0.011	0.024	0.035	0.070 (Combined)
5/18/2018	2AL - Post Lag Filter - Top	0.046	0.029	0.075	0.070 (Combined)
5/18/2018	2AL - Post Lag Filter - Bottom	ND	0.0065	0.0065	0.070 (Combined)
5/18/2018	4AL - Raw	0.032	0.015	0.047	0.070 (Combined)
5/18/2018	4AL - Post Lead Filter	0.024	0.019	0.043	0.070 (Combined)
5/18/2018	4AL - Post Lag Filter (finished wate	0.0097	0.015	0.0247	0.070 (Combined)
5/18/2018	10AL - Raw	0.031	0.022	0.053	0.070 (Combined)
5/18/2018	10AL - Post Lead Filter	ND	ND	0	0.070 (Combined)
5/18/2018	10AL - Post Lag Filter (finished wat	0.0026	ND	0.0026	0.070 (Combined)
5/23/2018	2AL - Post Lag Filter - Bottom	0.013	0.013	0.026	0.070 (Combined)
5/23/2018	10AL - Raw	0.034	0.018	0.052	0.070 (Combined)
5/23/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
5/30/2018	2AL - Post Lag Filter - Bottom	0.013	0.016	0.029	0.070 (Combined)
5/30/2018	10AL - Raw	0.032	0.019	0.051	0.070 (Combined)
5/30/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
6/6/2018	2AL - Post Lag Filter - Bottom	0.018	0.019	0.037	0.070 (Combined)
6/6/2018	10AL - Raw	0.034	0.022	0.056	0.070 (Combined)
6/6/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
6/14/2018	2AL - Post Lag Filter - Bottom	0.021	0.019	0.04	0.070 (Combined)
6/20/2018	2AL - Raw	0.14	0.038	0.178	0.070 (Combined)
6/20/2018	2AL - Post Lead Filter - Bottom	0.025	0.036	0.061	0.070 (Combined)
6/20/2018	2AL - Post Lag Filter - Bottom	0.006	0.017	0.023	0.070 (Combined)
6/20/2018	4AL - Raw	0.03	0.017	0.047	0.070 (Combined)
6/20/2018	4AL - Post Lead Filter	0.027	0.021	0.048	0.070 (Combined)
6/20/2018	4AL - Post Lag Filter (finished wate	0.013	0.022	0.035	0.070 (Combined)
6/20/2018	10AL - Raw	0.034	0.02	0.054	0.070 (Combined)
6/20/2018	10AL - Post Lead Filter	ND	ND	0	0.070 (Combined)
6/20/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
6/20/2018	SAL	0.0026	0.018	0.0206	0.070 (Combined)
6/20/2018	9AL	0.021	0.013	0.034	0.070 (Combined)
6/20/2018	TW1	ND	ND	ND	0.070 (Combined)
6/20/2018	TW2	ND	ND	ND	0.070 (Combined)
6/20/2018	TW4	ND	0.0042	0.0042	0.070 (Combined)
6/20/2018	TW5	ND	0.0039	0.0039	0.070 (Combined)
6/20/2018	TW6	ND	0.004	0.004	0.070 (Combined)
6/20/2018	20B Raw	ND	ND	ND	0.070 (Combined)
6/20/2018	EPDS 001 (TWR)	ND	0.0034	0.0034	0.070 (Combined)
6/20/2018	EPDS 002 (20B ATF)	0.0055	0.0051	0.0106	0.070 (Combined)
6/20/2018	EPDS 003 (ALR)	0.012	0.01	0.022	0.070 (Combined)
6/20/2018	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
7/11/2018	2AL - Raw	0.12	0.037	0.157	0.070 (Combined)
7/11/2018	2AL - Post Lead Filter - Bottom	0.081	0.036	0.117	0.070 (Combined)
7/11/2018	2AL - Post Lag Filter - Bottom	0.078	0.033	0.111	0.070 (Combined)
7/11/2018	4AL - Raw	0.03	0.016	0.046	0.070 (Combined)
7/11/2018	4AL - Post Lead Filter	0.03	0.022	0.052	0.070 (Combined)
7/11/2018	4AL - Post Lag Filter	0.019	0.025	0.044	0.070 (Combined)
7/11/2018	10AL - Raw	0.033	0.022	0.055	0.070 (Combined)
7/11/2018	10AL - Post Lead Filter	ND	ND	0	0.070 (Combined)
7/11/2018	10AL - Post Lag Filter	ND	ND	0	0.070 (Combined)
7/11/2018	SAL	0.0027	0.004	0.0067	0.070 (Combined)
7/11/2018	9AL	0.02	0.012	0.032	0.070 (Combined)
7/11/2018	TW1	ND	ND	ND	0.070 (Combined)
7/11/2018	TW2	0.0019	0.002	0.0039	0.070 (Combined)
7/11/2018	TW4	ND	0.0042	0.0042	0.070 (Combined)
7/11/2018	TW5	ND	0.0039	0.0039	0.070 (Combined)
7/11/2018	TW6	ND	0.004	0.004	0.070 (Combined)
7/11/2018	20B Raw	ND	ND	ND	0.070 (Combined)
7/11/2018	EPDS 001 (TWR)	ND	0.0038	0.0038	0.070 (Combined)
7/11/2018	EPDS 002 (20B ATF)	0.0077	0.005	0.0127	0.070 (Combined)
7/11/2018	EPDS 003 (ALR)	0.015	0.012	0.027	0.070 (Combined)
7/11/2018	EPDS 006 (34C)	0.002	ND	0.002	0.070 (Combined)
8/6/2018	2AL - Post Lag Filter - Bottom	0.042	0.031	0.073	0.070 (Combined)
8/16/2018	4AL - Post Lag Filter (finished wate	0.025	0.028	0.053	0.070 (Combined)
8/16/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
9/13/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
10/23/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)
11/15/2018	10AL - Post Lag Filter (finished wat	ND	ND	0	0.070 (Combined)

2017 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level
3/29/2017	4AL - Raw	0.052	0.027	0.079	0.070 (Combined)
3/29/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
3/29/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
4/18/2017	Tanner Gate - 5AL & 9AL	0.015	0.0076	0.0226	0.070 (Combined)
4/26/2017	5AL	0.0026	0.0032	0.0058	0.070 (Combined)
4/26/2017	9AL	0.024	0.012	0.036	0.070 (Combined)
4/26/2017	TW2	ND	ND	ND	0.070 (Combined)
4/26/2017	TW4	ND	0.0034	0.0034	0.070 (Combined)
4/26/2017	TW5	ND	0.0032	0.0032	0.070 (Combined)
4/26/2017	TW6	ND	0.0032	0.0032	0.070 (Combined)
4/26/2017	EPDS 001	ND	0.0026	0.0026	0.070 (Combined)
4/26/2017	EPDS 003	0.014	0.0075	0.0215	0.070 (Combined)
4/26/2017	EPDS 005	0.028	0.022	0.05	0.070 (Combined)
4/26/2017	EPDS 006	ND	ND	ND	0.070 (Combined)
5/5/2017	4AL - Raw	0.042	0.02	0.062	0.070 (Combined)
5/5/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
5/5/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
5/22/2017	4AL - Raw	0.039	0.022	0.061	0.070 (Combined)
5/22/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
5/22/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
5/30/2017	4AL - Raw	0.034	0.018	0.052	0.070 (Combined)
5/30/2017	5AL	ND	0.0033	0.0033	0.070 (Combined)
5/30/2017	9AL	0.026	0.012	0.038	0.070 (Combined)
5/30/2017	TW2	ND	ND	ND	0.070 (Combined)
5/30/2017	TW4	ND	0.0033	0.0033	0.070 (Combined)
5/30/2017	TW5	ND	0.0028	0.0028	0.070 (Combined)
5/30/2017	TW6	ND	0.0033	0.0033	0.070 (Combined)
5/30/2017	EPDS 001	ND	0.003	0.003	0.070 (Combined)
5/30/2017	EPDS 003	0.0087	0.0051	0.0138	0.070 (Combined)
5/30/2017	EPDS 005	0.032	0.024	0.056	0.070 (Combined)
5/30/2017	EPDS 006	ND	ND	ND	0.070 (Combined)
6/22/2017	2AL - Raw	0.14	0.042	0.182	0.070 (Combined)
6/22/2017	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
6/22/2017	2AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
6/22/2017	4AL - Raw	0.028	0.014	0.042	0.070 (Combined)
6/22/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
6/22/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
6/22/2017	5AL	ND	0.003	0.003	0.070 (Combined)
6/22/2017	9AL	0.023	0.012	0.035	0.070 (Combined)
6/22/2017	TW2	ND	ND	ND	0.070 (Combined)
6/22/2017	TW4	ND	0.0032	0.0032	0.070 (Combined)
6/22/2017	TW5	ND	0.0029	0.0029	0.070 (Combined)
6/22/2017	TW6	ND	0.0035	0.0035	0.070 (Combined)
6/22/2017	EPDS 001	ND	0.0029	0.0029	0.070 (Combined)
6/22/2017	EPDS 003	0.0093	0.0029	0.0122	0.070 (Combined)
6/22/2017	EPDS 005	0.028	0.021	0.049	0.070 (Combined)
6/22/2017	EPDS 006	ND	ND	ND	0.070 (Combined)
7/7/2017	2AL - Raw	0.15	0.034	0.184	0.070 (Combined)
7/7/2017	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
7/7/2017	2AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
7/7/2017	4AL - Raw	0.024	0.012	0.036	0.070 (Combined)
7/7/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
7/7/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
7/21/2017	4AL - Raw	0.027	0.014	0.041	0.070 (Combined)
7/21/2017	4AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
7/21/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
7/21/2017	5AL	ND	0.0028	0.0028	0.070 (Combined)
7/21/2017	9AL	0.023	0.011	0.034	0.070 (Combined)
7/21/2017	TW1	ND	ND	ND	0.070 (Combined)
7/21/2017	TW2	ND	ND	ND	0.070 (Combined)
7/21/2017	TW5	ND	0.0029	0.0029	0.070 (Combined)
7/21/2017	TW6	ND	0.0034	0.0034	0.070 (Combined)
7/21/2017	EPDS 001	ND	0.0028	0.0028	0.070 (Combined)
7/21/2017	EPDS 002	ND	ND	ND	0.070 (Combined)
7/21/2017	EPDS 003	0.0085	0.0057	0.0142	0.070 (Combined)
7/21/2017	EPDS 006	ND	ND	ND	0.070 (Combined)
8/28/2017	4AL - Raw	0.028	0.014	0.042	0.070 (Combined)
8/28/2017	4AL - Post Lead Filter	ND	0.0026	0.0026	0.070 (Combined)
8/28/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
8/28/2017	5AL	ND	0.0028	0.0028	0.070 (Combined)
8/28/2017	9AL	0.022	0.011	0.033	0.070 (Combined)
8/28/2017	TW1	ND	ND	ND	0.070 (Combined)
8/28/2017	TW2	ND	ND	ND	0.070 (Combined)
8/28/2017	TW5	ND	0.0029	0.0029	0.070 (Combined)
8/28/2017	TW6	ND	0.003	0.003	0.070 (Combined)
8/28/2017	208 Raw	ND	ND	ND	0.070 (Combined)
8/28/2017	EPDS 001	ND	0.0027	0.0027	0.070 (Combined)
8/28/2017	EPDS 002	ND	ND	ND	0.070 (Combined)
8/28/2017	EPDS 003	0.0071	0.0046	0.0117	0.070 (Combined)
8/28/2017	EPDS 005	0.028	0.02	0.048	0.070 (Combined)
8/28/2017	EPDS 006	ND	ND	ND	0.070 (Combined)
9/22/2017	2AL - Raw	0.16	0.034	0.194	0.070 (Combined)
9/22/2017	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
9/22/2017	2AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
9/22/2017	4AL - Raw	0.029	0.016	0.045	0.070 (Combined)
9/22/2017	4AL - Post Lead Filter	0.0029	0.0044	0.0073	0.070 (Combined)
9/22/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
9/22/2017	5AL	ND	0.0029	0.0029	0.070 (Combined)
9/22/2017	9AL	0.021	0.012	0.033	0.070 (Combined)
9/22/2017	TW1	ND	ND	ND	0.070 (Combined)
9/22/2017	TW2	ND	ND	ND	0.070 (Combined)
9/22/2017	TW6	ND	0.003	0.003	0.070 (Combined)
9/22/2017	208 Raw	ND	ND	ND	0.070 (Combined)
9/22/2017	EPDS 005 (10AL)	0.027	0.021	0.048	0.070 (Combined)
9/22/2017	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
9/29/2017	6AL	ND	ND	ND	0.070 (Combined)
10/23/2017	Marbella Well	ND	ND	ND	0.070 (Combined)
10/27/2017	2AL - Raw	0.17	0.034	0.204	0.070 (Combined)
10/27/2017	2AL - Post Lead Filter	ND	ND	ND	0.070 (Combined)
10/27/2017	2AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
10/27/2017	4AL - Raw	0.027	0.013	0.04	0.070 (Combined)
10/27/2017	4AL - Post Lead Filter	0.0062	0.0076	0.0138	0.070 (Combined)
10/27/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
10/27/2017	5AL	ND	0.0027	0.0027	0.070 (Combined)
10/27/2017	9AL	0.021	0.012	0.033	0.070 (Combined)
10/27/2017	TW1	ND	ND	ND	0.070 (Combined)
10/27/2017	TW2	ND	ND	ND	0.070 (Combined)
10/26/2017	TW4	ND	0.0036	0.0036	0.070 (Combined)
10/27/2017	TW5	ND	0.0031	0.0031	0.070 (Combined)
10/27/2017	TW6	ND	0.0029	0.0029	0.070 (Combined)
10/27/2017	208 Raw	ND	ND	ND	0.070 (Combined)
10/27/2017	EPDS 005 (10AL)	0.029	0.019	0.048	0.070 (Combined)
10/27/2017	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
10/27/2017	EPDS 001 (TWR)	ND	0.0025	0.0025	0.070 (Combined)
10/27/2017	EPDS 003 (ALR)	ND	ND	ND	0.070 (Combined)
11/27/2017	2AL - Raw	0.14	0.029	0.169	0.070 (Combined)
11/27/2017	2AL - Post Lead Filter - Midpoint	0.0066	0.0045	0.0111	0.070 (Combined)
11/27/2017	2AL - Post Lag Filter - Top	ND	ND	ND	0.070 (Combined)
11/27/2017	4AL - Raw	0.031	0.014	0.045	0.070 (Combined)
11/27/2017	4AL - Post Lead Filter	0.0085	0.0094	0.0179	0.070 (Combined)
11/27/2017	4AL - Post Lag Filter (finished water,	ND	ND	ND	0.070 (Combined)
11/27/2017	5AL	0.0025	0.0029	0.0054	0.070 (Combined)
11/27/2017	TW2	ND	ND	ND	0.070 (Combined)
11/27/2017	TW5	ND	0.0031	0.0031	0.070 (Combined)
11/27/2017	208 Raw	ND	ND	ND	0.070 (Combined)
11/27/2017	EPDS 002 (208 Blended)	ND	ND	ND	0.070 (Combined)
11/27/2017	EPDS 005 (10AL)	0.029	0.019	0.048	0.070 (Combined)
11/27/2017	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
11/27/2017	EPDS 001 (TWR)	ND	0.0028	0.0028	0.070 (Combined)
11/27/2017	EPDS 003 (ALR)	ND	0.0026	0.0026	0.070 (Combined)
12/20/2017	2AL - Raw	0.15	0.03	0.18	0.070 (Combined)
12/20/2017	2AL - Post Lead Filter - Bottom	ND	ND	ND	0.070 (Combined)
12/20/2017	2AL - Post Lag Filter - Top	ND	ND	ND	0.070 (Combined)
12/20/2017	4AL - Raw	0.029	0.013	0.042	0.070 (Combined)
12/20/2017	4AL - Post Lead Filter	0.01	0.0097	0.0197	0.070 (Combined)
12/20/2017	4AL - Post Lag Filter (finished water,	ND	0.0033	0.0033	0.070 (Combined)
12/20/2017	5AL	0.0033	0.004	0.0073	0.070 (Combined)
12/20/2017	TW2	ND	ND	ND	0.070 (Combined)
12/20/2017	EPDS 005 (10AL)	0.031	0.018	0.049	0.070 (Combined)
12/20/2017	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)
12/20/2017	EPDS 001 (TWR)	ND	ND	ND	0.070 (Combined)
12/20/2017	EPDS 003 (ALR)	ND	0.0031	0.0031	0.070 (Combined)

## 2016 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level	Other PFAs
2/25/2016	2AL Raw	0.2	0.05	0.25	0.070 (Combined)	
2/25/2016	10AL	ND	0.02	0.02	0.070 (Combined)	
4/20/2016	4AL	0.110	0.034	0.144	0.070 (Combined)	0.0635
	5AL	0.0055	0.0060	0.0115	0.070 (Combined)	0.0100
	9AL	0.035	0.015	0.050	0.070 (Combined)	0.0206
	10AL	0.029	0.023	0.052	0.070 (Combined)	0.0634
5/11/2016	2AL Raw	0.19	0.044	0.234	0.070 (Combined)	0.1331
5/26/2016	ALR Influent	0.019	0.0096	0.0286	0.070 (Combined)	0.0141
	ALR Post Treatment	0.019	0.0093	0.0283	0.070 (Combined)	0.0135
	EPDS 003 (ALR)	0.019	0.0094	0.0284	0.070 (Combined)	0.0135
5/26/2016	TWR Influent	ND	ND	ND	0.070 (Combined)	0.0034
	TWR Post Treatment	ND	ND	ND	0.070 (Combined)	0.0032
	EPDS 001 (TWR)	ND	0.0029	0.0029	0.070 (Combined)	0.0042
5/26/2016	EPDS 006 (34C)	ND	ND	ND	0.070 (Combined)	ND
5/26/2016	5AL	ND	0.0028	0.0028	0.070 (Combined)	0.0046
5/26/2016	9AL	0.034	0.015	0.049	0.070 (Combined)	0.0203
5/26/2016	Goodyear West Interconnect	ND	0.0036	0.0036	0.070 (Combined)	0.0062
7/1/2016	2AL Raw	0.190	0.045	0.235	0.070 (Combined)	0.1359
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
7/14/2016	2AL Post Lead	ND	ND	ND	0.070 (Combined)	
7/17/2016	4AL	0.100	0.033	0.133	0.070 (Combined)	0.0643
7/27/2016	4AL	0.074	0.024	0.098	0.070 (Combined)	
7/29/2016	2AL Raw	0.18	0.044	0.224	0.070 (Combined)	0.116
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	ND
8/5/2016	2AL Post Lead	ND	ND	ND	0.070 (Combined)	
8/22/2016	2AL Raw	0.19	0.037	0.227	0.070 (Combined)	
	2AL Post Lead	0.016	0.0048	0.0208	0.070 (Combined)	
9/27/2016	4AL	0.069	0.032	0.101	0.070 (Combined)	
9/27/2016	2AL Post Lead	0.028	0.0095	0.0375	0.070 (Combined)	
10/10/2016	2AL Post Lead	0.03	0.0062	0.0362	0.070 (Combined)	
	2AL Post Lag (finished water)	ND	ND	ND	0.070 (Combined)	
10/20/2016	2AL Raw	0.19	0.045	0.235	0.070 (Combined)	
	2AL Post Lead	0.053	0.018	0.071	0.070 (Combined)	
	2AL Post Lag (finished water)	0.0047	ND	0.0047	0.070 (Combined)	
10/26/2016	2AL Raw	0.23	0.042	0.272	0.070 (Combined)	
	2AL Post Lead	0.051	0.016	0.067	0.070 (Combined)	
	2AL Post Lag (finished water)	0.0042	0.004	0.0082	0.070 (Combined)	
11/2/2016	2AL Raw	0.18	0.041	0.221	0.070 (Combined)	
	2AL Post Lead	0.056	0.018	0.074	0.070 (Combined)	
	2AL Post Lag (finished water)	0.0086	0.0038	0.0124	0.070 (Combined)	
11/10/2016	5AL Raw	ND	0.0032	0.0032	0.070 (Combined)	
	9AL Raw	0.028	0.014	0.042	0.070 (Combined)	
	TW5 Raw	ND	0.0034	0.0034	0.070 (Combined)	
	TW1 Raw	ND	ND	ND	0.070 (Combined)	
	TW2 Raw	ND	ND	ND	0.070 (Combined)	
	34C Raw - EPDS 006	ND	ND	ND	0.070 (Combined)	
11/16/2016	4AL Raw	0.064	0.028	0.092	0.070 (Combined)	
	EPDS 003 - 10AL Raw	0.044	0.025	0.069	0.070 (Combined)	
	TW4 Raw	ND	0.0028	0.0028	0.070 (Combined)	
	TW6 Raw	ND	0.0028	0.0028	0.070 (Combined)	
	20B Raw	ND	ND	ND	0.070 (Combined)	
11/17/2016	6AL 1st Draw	0.042	0.025	0.067	0.070 (Combined)	

## 2014 PFOS/PFOA Summary

Results are listed in µg/L

Sample Date	Location	PFOS Result	PFOA Result	Combined Result	PFOS/PFOA EPA Advisory Level
5/6/2014	EPDS 002 (20B ATF)	ND	ND	ND	0.070 (Combined)
5/6/2014	EPDS 003 (Airline Reservoir)	ND	ND	ND	0.070 (Combined)
5/6/2014	EPDS 001 (Townwell Reservoir)	ND	ND	ND	0.070 (Combined)
5/15/2014	EPDS 005 (Well 10AL)	ND	ND	ND	0.070 (Combined)
5/15/2014	EPDS 006 (Well 34C)	ND	ND	ND	0.070 (Combined)
5/29/2014	EPDS 004 (Well 2AL)	0.22	0.05	0.27	0.070 (Combined)
11/5/2014	EPDS 001 (Townwell Reservoir)	ND	ND	ND	0.070 (Combined)
11/5/2014	EPDS 002 (20B ATF)	ND	ND	ND	0.070 (Combined)
11/6/2014	EPDS 003 (Airline Reservoir)	ND	ND	ND	0.070 (Combined)
11/6/2014	EPDS 005 (Well 10AL)	ND	ND	ND	0.070 (Combined)
11/18/2014	EPDS 004 (Well 2AL)	0.19	0.05	0.24	0.070 (Combined)
11/19/2014	EPDS 006 (Well 34C)	ND	ND	ND	0.070 (Combined)

PFOS/PFOA Summary for 2AL (EPDS 004)

Results are listed in µg/L

Well Reg. # 55-611724

EPA

Sample Date	2AL Raw			Other PFAs	2AL Post Lead			2AL Post Lag (finished water)			Other PFAs	EPA Target Less Than
	PFOS	PFOA	Combined		PFOS	PFOA	Combined	PFOS	PFOA	Combined		
5/29/2014	0.22	0.05	0.27									0.070
11/18/2014	0.19	0.05	0.24									0.070
2/25/2016	0.20	0.05	0.25									0.070
5/11/2016	0.19	0.044	0.234	0.1331								0.070
7/1/2016	0.19	0.045	0.235	0.1359				ND	ND	ND		0.070
7/14/2016					ND	ND	ND					0.070
7/29/2016	0.18	0.044	0.224	0.116				ND	ND	ND		0.070
8/5/2016					ND	ND	ND					0.070
8/22/2016	0.19	0.037	0.227		0.016	0.0048	0.0208					0.070
9/27/2016					0.028	0.0095	0.0375					0.070
10/10/2016					0.03	0.0062	0.0362	ND	ND	ND		0.070
10/20/2016	0.19	0.045	0.235		0.053	0.018	0.071	0.0047	ND	0.0047		0.070
10/26/2016	0.23	0.042	0.272		0.051	0.016	0.067	0.0042	0.004	0.0082		0.070
11/2/2016	0.18	0.041	0.221		0.056	0.018	0.074	0.0086	0.0038	0.0124		0.070
6/22/2017	0.14	0.042	0.182		ND	ND	ND	ND	ND	ND		0.070
7/7/2017	0.15	0.034	0.184		ND	ND	ND	ND	ND	ND		0.070
9/22/2017	0.16	0.034	0.194		ND	ND	ND	ND	ND	ND		0.070
10/27/2017	0.17	0.034	0.204		ND	ND	ND	ND	ND	ND		0.070
11/27/2017	0.14	0.029	0.169		0.0066	0.0045	0.0111	ND	ND	ND		0.070
12/20/2017	0.15	0.03	0.18		ND	ND	ND	ND	ND	ND		0.070
1/25/2018	0.15	0.033	0.183		ND	ND	ND	ND	0.003	0.003		0.070
2/23/2018	0.15	0.035	0.185		ND	0.0058	0.0058	0.006	0.0086	0.0146		0.070
3/23/2018	0.14	0.033	0.173		ND	0.0089	0.0089	ND	0.0047	0.0047		0.070
4/17/2018	0.13	0.033	0.163		0.046	0.021	0.067	0.005	0.008	0.013		0.070
5/9/2018	0.13	0.0033	0.1333					0.0067	0.0099	0.0166		0.070
5/18/2018	0.16	0.037	0.197		0.011	0.024	0.035	ND	0.0065	0.0065		0.070
5/23/2018								0.013	0.013	0.026		0.070
5/30/2018								0.013	0.016	0.029		0.070
6/6/2018								0.018	0.019	0.037		0.070
6/14/2018								0.021	0.019	0.040		0.070
6/20/2018	0.14	0.038	0.178		0.025	0.036	0.061	0.006	0.017	0.023		0.070
7/11/2018	0.12	0.037	0.157		0.081	0.036	0.117	0.078	0.033	0.111		0.070
8/6/2018								0.042	0.031	0.073		0.070
3/13/2019					ND	ND	ND	ND	ND	ND		0.070
4/22/2019	0.16	0.04	0.200					ND	ND	ND		0.070
5/22/2019								ND	ND	ND		0.070
6/20/2019								ND	ND	ND		0.070
7/24/2019								ND	ND	ND		0.070
8/22/2019								ND	ND	ND		0.070
10/23/2019	0.12	0.038	0.158		0.011	0.012	0.023	ND	ND	ND		0.070
2/12/2020					0.023	0.020	0.043	ND	0.0039	0.0039		0.070
4/23/2020					ND	ND	ND	ND	ND	ND		0.070
5/22/2020	0.16	0.044	0.204	0.152				ND	ND	ND		0.070
6/23/2020								ND	ND	ND		0.070
7/22/2020								ND	ND	ND		0.070
8/19/2020	0.15	0.037	0.187	0.1408	0.015	0.011	0.026	ND	ND	ND		0.070
9/23/2020								ND	ND	ND	0.0253	0.070
10/27/2020								0.0024	0.0044	0.0068	0.0514	0.070

Well taken off line on 9/5/2018 af



ter receiving previous results.

PFOS/PFOA Summary for 4AL

Results are listed in µg/L

Well Reg. # 55-611726

EPA

Sample Date	4AL Raw				4AL Post Lead				4AL Post Lag (finished water)				EPA Target Less Than
	PFOS	PFOA	Combined	Other PFAs	PFOS	PFOA	Combined	Other PFAs	PFOS	PFOA	Combined	Other PFAs	
4/20/2016	0.110	0.034	0.144	0.0635									0.070
7/27/2016	0.074	0.024	0.098										0.070
9/27/2016	0.069	0.032	0.101										0.070
11/16/2016	0.064	0.028	0.092										0.070
3/29/2017	0.052	0.027	0.079		ND	ND	ND		ND	ND	ND		0.070
5/5/2017	0.042	0.02	0.062		ND	ND	ND		ND	ND	ND		0.070
5/22/2017	0.039	0.022	0.061		ND	ND	ND		ND	ND	ND		0.070
5/30/2017	0.034	0.018	0.052										0.070
6/22/2017	0.028	0.014	0.042		ND	ND	ND		ND	ND	ND		0.070
7/7/2017	0.024	0.012	0.036		ND	ND	ND		ND	ND	ND		0.070
7/21/2017	0.027	0.014	0.041		ND	ND	ND		ND	ND	ND		0.070
8/28/2017	0.028	0.014	0.042		ND	0.0026	0.0026		ND	ND	ND		0.070
9/22/2017	0.029	0.016	0.045		0.0029	0.0044	0.0044		ND	ND	ND		0.070
10/27/2017	0.027	0.013	0.040		0.0062	0.0076	0.0076		ND	ND	ND		0.070
11/27/2017	0.031	0.014	0.045		0.0085	0.0094	0.0094		ND	ND	ND		0.070
12/20/2017	0.029	0.013	0.042		0.01	0.0097	0.0097		ND	0.0033	0.0033		0.070
1/25/2018	0.033	0.015	0.048		0.014	0.012	0.012		ND	0.005	0.005		0.070
2/23/2018	0.033	0.017	0.05		0.018	0.016	0.016		0.0031	0.0085	0.0116		0.070
3/23/2018	0.03	0.016	0.046		0.016	0.014	0.014		0.0048	0.01	0.0148		0.070
4/17/2018	0.03	0.016	0.046		0.016	0.014	0.014		0.0048	0.01	0.0148		0.070
5/18/2018	0.032	0.015	0.047		0.024	0.019	0.019		0.0097	0.015	0.0247		0.070
6/20/2018	0.03	0.017	0.047		0.027	0.021	0.021		0.013	0.022	0.035		0.070
7/11/2018	0.03	0.016	0.046		0.03	0.022	0.022		0.019	0.025	0.044		0.070
8/16/2018									0.025	0.028	0.053		0.070
7/24/2019									ND	ND	ND		0.070
8/22/2019									ND	ND	ND		0.070
9/24/2019									ND	ND	ND		0.070
10/23/2019	0.019	0.014	0.033		ND	ND	ND		ND	ND	ND		0.070
11/19/2019									ND	ND	ND		0.070
2/12/2020					0.0036	0.0086	0.0086		ND	ND	ND		0.070
4/23/2020					ND	ND	ND		ND	ND	ND		0.070
5/22/2020	0.03	0.017	0.047	0.043					ND	ND	ND		0.070
6/23/2020									ND	ND	ND		0.070
7/22/2020									ND	ND	ND		0.070
8/19/2020	0.028	0.016	0.044	0.0409	0.0022	0.005	0.0072		ND	ND	ND		0.070
9/23/2020									ND	ND	ND	0.0168	0.070
10/27/2020									ND	0.0029	0.0029	0.0249	0.070
11/30/2020	0.035	0.017	0.052	0.0467	0.013	0.015	0.0280	0.0507	ND	0.0058	0.0058	0.0359	0.070
12/21/2020					0.0023	0.0080	0.0103		0.0045	0.012	0.0165	0.0448	0.070
1/27/2021	0.035	0.017	0.052	0.0461	0.023	0.02	0.0430	0.0566	0.0045	0.012	0.0165	0.0448	0.070
2/24/2021									ND	ND	ND	0.0853	0.070

PFOS/PFOA Summary for 10AL (EPDS 005)

Results are listed in µg/L

Well Reg. # 55-214539

EPA

Sample Date	10AL Raw			Other PFAs	10AL Post Lead			Other PFAs	10AL Post Lag (finished water)				EPA Target Less Than
	PFOS	PFOA	Combined		PFOS	PFOA	Combined		PFOS	PFOA	Combined	Other PFAs	
5/15/2014	ND	ND	ND										0.070
11/6/2014	ND	ND	ND										0.070
2/25/2016	ND	0.020	0.020										0.070
4/20/2016	0.029	0.023	0.052	0.0634									0.070
11/16/2016	0.044	0.025	0.069										0.070
4/26/2017	0.028	0.022	0.050										0.070
5/30/2017	0.032	0.024	0.056										0.070
6/22/2017	0.028	0.021	0.049										0.070
8/28/2017	0.028	0.020	0.048										0.070
9/22/2017	0.027	0.021	0.048										0.070
10/27/2017	0.029	0.019	0.048										0.070
11/27/2017	0.029	0.019	0.048										0.070
12/20/2017	0.031	0.018	0.049										0.070
2/23/2018	0.034	0.022	0.056										0.070
3/13/2018	0.031	0.021	0.052										0.070
4/10/2018	0.031	0.02	0.051						ND	ND	ND	ND	0.070
4/17/2018	0.031	0.02	0.051		ND	ND	ND		ND	ND	ND	ND	0.070
5/7/2018	0.031	0.019	0.05		ND	ND	ND		ND	ND	ND	ND	0.070
5/18/2018	0.031	0.022	0.053		ND	ND	ND		0.026	ND	0.026	0.026	0.070
5/23/2018	0.034	0.018	0.052						ND	ND	ND	ND	0.070
5/30/2018	0.032	0.019	0.051						ND	ND	ND	ND	0.070
6/6/2018	0.034	0.022	0.056						ND	ND	ND	ND	0.070
6/20/2018	0.034	0.02	0.054		ND	ND	ND		ND	ND	ND	ND	0.070
7/11/2018	0.033	0.022	0.055		ND	ND	ND		ND	ND	ND	ND	0.070
8/16/2018									ND	ND	ND	ND	0.070
9/13/2018									ND	ND	ND	ND	0.070
10/23/2018									ND	ND	ND	ND	0.070
11/15/2018									ND	ND	ND	ND	0.070
1/25/2019									ND	ND	ND	ND	0.070
2/22/2019									ND	ND	ND	ND	0.070
3/20/2019									ND	ND	ND	ND	0.070
4/22/2019	0.025	0.020	0.045		ND	0.0020	0.0020		ND	ND	ND	ND	0.070
5/22/2019					ND	0.0057	0.0057		ND	ND	ND	ND	0.070
6/20/2019					ND	0.0070	0.0070		ND	ND	ND	ND	0.070
7/24/2019					ND	0.0130	0.0130		ND	ND	ND	ND	0.070
8/22/2019					ND	0.0130	0.0130		ND	ND	ND	ND	0.070
10/23/2019	0.039	0.018	0.057		0.0036	0.0180	0.0036		ND	ND	ND	ND	0.070
5/22/2020	0.043	0.018	0.061	0.060	ND	ND	ND		ND	ND	ND	ND	0.070
6/23/2020									ND	ND	ND	ND	0.070
7/22/2020									ND	ND	ND	ND	0.070
8/19/2020	0.044	0.018	0.062	0.0643	ND	ND	ND		ND	ND	ND	ND	0.070
10/27/2020									ND	ND	ND	ND	0.070
11/30/2020	0.052	0.020	0.072	0.0714	ND	ND	ND		ND	ND	ND	ND	0.070
1/27/2021	0.052	0.018	0.070	0.0661	ND	ND	ND	0.0031	ND	ND	ND	ND	0.070
2/24/2021									ND	ND	ND	ND	0.070

## PFOS/PFOA Summary for 5AL

Results are listed in µg/L

Well Reg.	#	55-611727			EPA
Sample Date	<b>5AL Raw</b>			Other	Target
	PFOS	PFOA	Combined	PFAs	Less Than
4/20/2016	0.0055	0.0060	0.0115	0.0100	0.070 (Combined)
5/26/2016	ND	0.0028	0.0028	0.0046	0.070 (Combined)
11/10/2016	ND	0.0032	0.0032		0.070 (Combined)
4/26/2017	0.0026	0.0032	0.0058		0.070 (Combined)
5/30/2017	ND	0.0033	0.0033		0.070 (Combined)
6/22/2017	ND	0.003	0.003		0.070 (Combined)
7/21/2017	ND	0.0028	0.0028		0.070 (Combined)
8/28/2017	ND	0.0028	0.0028		0.070 (Combined)
9/22/2017	ND	0.0029	0.0029		0.070 (Combined)
10/27/2017	ND	0.0027	0.0027		0.070 (Combined)
11/27/2017	0.0025	0.0029	0.0054		0.070 (Combined)
12/20/2017	0.0033	0.004	0.0073		0.070 (Combined)
3/23/2018	0.0031	0.0045	0.0076		0.070 (Combined)
4/17/2018	ND	0.0034	0.0034		0.070 (Combined)
5/18/2018	0.0026	0.0036	0.0062		0.070 (Combined)
6/20/2018	0.0026	0.018	0.0206		0.070 (Combined)
7/11/2018	0.0027	0.004	0.0067		0.070 (Combined)
5/22/2020	0.0053	0.0068	0.0121	0.0176	0.070 (Combined)
8/19/2020	0.0051	0.0062	0.0113	0.0174	0.070 (Combined)
11/30/2020	0.0056	0.0069	0.0125	0.0187	0.070 (Combined)
1/27/2021	0.0065	0.0074	0.0139	0.0202	0.070 (Combined)

## PFOS/PFOA Summary for 6AL

Results are listed in µg/L

Well Reg.	#	55-611728			EPA Target Less Than	
Sample Date	PFOS	<b>6AL Raw</b> PFOA	Combined	Other PFAs		
11/17/2016	0.042	0.025	0.067		0.070 (Combined)	1st Draw
9/29/2017	ND	ND	ND		0.070 (Combined)	Initial Test
5/22/2020	0.0032	0.0037	0.0069	0.0085	0.070 (Combined)	
8/19/2020	0.0031	0.0034	0.0065	0.0082	0.070 (Combined)	
11/30/2020	0.0036	0.0042	0.0078	0.0117	0.070 (Combined)	
1/27/2021	0.0037	0.0045	0.0082	0.0123	0.070 (Combined)	

## PFOS/PFOA Summary for 9AL

Results are listed in µg/L

Well Reg.	#	55-611729			EPA
Sample Date	<b>9AL Raw</b>			Other	Target
	PFOS	PFOA	Combined	PFAs	Less Than
4/20/2016	0.035	0.015	0.050	0.0206	0.070 (Combined)
5/26/2016	0.034	0.015	0.049	0.0203	0.070 (Combined)
11/10/2016	0.028	0.014	0.042		0.070 (Combined)
4/26/2017	0.024	0.012	0.036		0.070 (Combined)
5/30/2017	0.026	0.012	0.038		0.070 (Combined)
6/22/2017	0.023	0.012	0.035		0.070 (Combined)
7/21/2017	0.023	0.011	0.034		0.070 (Combined)
8/28/2017	0.022	0.011	0.033		0.070 (Combined)
9/22/2017	0.021	0.012	0.033		0.070 (Combined)
10/27/2017	0.021	0.012	0.033		0.070 (Combined)
1/25/2018	0.015	0.011	0.026		0.070 (Combined)
2/23/2018	0.022	0.013	0.035		0.070 (Combined)
4/17/2018	0.02	0.012	0.032		0.070 (Combined)
5/18/2018	0.021	0.015	0.036		0.070 (Combined)
6/20/2018	0.021	0.013	0.034		0.070 (Combined)
7/11/2018	0.02	0.012	0.032		0.070 (Combined)
5/22/2020	0.021	0.015	0.036	0.0353	0.070 (Combined)
8/19/2020	0.02	0.014	0.034	0.0341	0.070 (Combined)

## PFOS/PFOA Summary for TW1

Results are listed in µg/L

Well Reg.	#	55-583454			EPA
Sample Date	<b>TW1 Raw</b>			Other	Target
	PFOS	PFOA	Combined	PFAs	Less Than
11/10/2016	ND	ND	ND		0.070 (Combined)
7/21/2017	ND	ND	ND		0.070 (Combined)
8/28/2017	ND	ND	ND		0.070 (Combined)
9/22/2017	ND	ND	ND		0.070 (Combined)
10/27/2017	ND	ND	ND		0.070 (Combined)
5/18/2018	ND	ND	ND		0.070 (Combined)
6/20/2018	ND	ND	ND		0.070 (Combined)
7/11/2018	ND	ND	ND		0.070 (Combined)
5/22/2020	ND	ND	ND	0.0032	0.070 (Combined)
8/19/2020	ND	ND	ND	0.0032	0.070 (Combined)
11/30/2020	ND	ND	ND	0.0039	0.070 (Combined)

## PFOS/PFOA Summary for TW2

Results are listed in µg/L

Well Reg.	#	55-611680			EPA
Sample Date	<b>TW2 Raw</b>			Other	Target
	PFOS	PFOA	Combined	PFAs	Less Than
11/10/2016	ND	ND	ND		0.070 (Combined)
4/26/2017	ND	ND	ND		0.070 (Combined)
5/30/2017	ND	ND	ND		0.070 (Combined)
6/22/2017	ND	ND	ND		0.070 (Combined)
7/21/2017	ND	ND	ND		0.070 (Combined)
8/28/2017	ND	ND	ND		0.070 (Combined)
9/22/2017	ND	ND	ND		0.070 (Combined)
10/27/2017	ND	ND	ND		0.070 (Combined)
11/27/2017	ND	ND	ND		0.070 (Combined)
12/20/2017	ND	ND	ND		0.070 (Combined)
1/25/2018	ND	ND	ND		0.070 (Combined)
2/23/2018	ND	ND	ND		0.070 (Combined)
3/23/2018	ND	ND	ND		0.070 (Combined)
4/17/2018	ND	ND	ND		0.070 (Combined)
5/18/2018	ND	ND	ND		0.070 (Combined)
6/20/2018	ND	ND	ND		0.070 (Combined)
7/11/2018	0.0019	0.002	0.0039		0.070 (Combined)
5/22/2020	0.0024	ND	0.0024	0.0057	0.070 (Combined)
8/19/2020	0.0026	ND	0.0026	0.0060	0.070 (Combined)
11/30/2020	0.0030	0.0022	0.0052	0.0090	0.070 (Combined)



## PFOS/PFOA Summary for TW4

Results are listed in µg/L

Well Reg.	#	55-611678			EPA
Sample Date	PFOS	<b>TW4 Raw</b>		Other	Target
		PFOA	Combined	PFAs	Less Than
11/16/2016	ND	0.0028	0.0028		0.070 (Combined)
4/26/2017	ND	0.0034	0.0034		0.070 (Combined)
5/30/2017	ND	0.0033	0.0033		0.070 (Combined)
6/22/2017	ND	0.0032	0.0032		0.070 (Combined)
10/26/2017	ND	0.0036	0.0036		0.070 (Combined)
4/17/2018	ND	0.0038	0.0038		0.070 (Combined)
5/18/2018	ND	0.0046	0.0046		0.070 (Combined)
6/20/2018	ND	0.0042	0.0042		0.070 (Combined)
7/11/2018	ND	0.0042	0.0042		0.070 (Combined)
5/22/2020	ND	0.005	0.005	0.0114	0.070 (Combined)
8/19/2020	ND	0.0049	0.0049	0.0120	0.070 (Combined)
11/30/2020	ND	0.0055	0.0055	0.0146	0.070 (Combined)
2/24/2021	ND	0.0054	0.0054	0.0127	0.070 (Combined)

## PFOS/PFOA Summary for TW5

Results are listed in µg/L

Well Reg.	#	55-611677			EPA
Sample Date	PFOS	<b>TW5 Raw</b>		Other PFAs	Target Less Than
		PFOA	Combined		
11/10/2016	ND	0.0034	0.0034		0.070 (Combined)
4/26/2017	ND	0.0032	0.0032		0.070 (Combined)
5/30/2017	ND	0.0028	0.0028		0.070 (Combined)
6/22/2017	ND	0.0029	0.0029		0.070 (Combined)
7/21/2017	ND	0.0029	0.0029		0.070 (Combined)
8/28/2017	ND	0.0029	0.0029		0.070 (Combined)
10/27/2017	ND	0.0031	0.0031		0.070 (Combined)
11/27/2017	ND	0.0031	0.0031		0.070 (Combined)
1/25/2018	ND	0.0031	0.0031		0.070 (Combined)
3/23/2018	ND	0.0037	0.0037		0.070 (Combined)
4/17/2018	ND	0.0037	0.0037		0.070 (Combined)
5/18/2018	ND	0.0039	0.0039		0.070 (Combined)
5/22/2020	ND	0.0056	0.0056	0.012	0.070 (Combined)
8/19/2020	ND	0.0043	0.0043	0.0125	0.070 (Combined)
11/30/2020	ND	0.0057	0.0057	0.0174	0.070 (Combined)
2/24/2021	ND	0.0058	0.0058	0.0160	0.070 (Combined)

## PFOS/PFOA Summary for TW6

Results are listed in µg/L

Well Reg.	#	55-533836			EPA
Sample Date	PFOS	<b>TW6 Raw</b>		Other PFAs	Target Less Than
		PFOA	Combined		
11/16/2016	ND	0.0028	0.0028		0.070 (Combined)
4/26/2017	ND	0.0032	0.0032		0.070 (Combined)
5/30/2017	ND	0.0033	0.0033		0.070 (Combined)
6/22/2017	ND	0.0035	0.0035		0.070 (Combined)
7/21/2017	ND	0.0034	0.0034		0.070 (Combined)
8/28/2017	ND	0.003	0.003		0.070 (Combined)
9/22/2017	ND	0.003	0.003		0.070 (Combined)
10/27/2017	ND	0.0029	0.0029		0.070 (Combined)
6/20/2018	ND	0.004	0.004		0.070 (Combined)
7/11/2018	ND	0.0038	0.0038		0.070 (Combined)
5/22/2020	ND	0.0048	0.0048	0.0024	0.070 (Combined)
8/19/2020	ND	0.0042	0.0042	0.0026	0.070 (Combined)
11/30/2020	ND	0.0046	0.0046	0.0031	0.070 (Combined)

## PFOS/PFOA Summary for 34C

Results are listed in µg/L

Well Reg.	#	55-611687			EPA
Sample Date	<b>34C Raw</b>			Other	Target
	PFOS	PFOA	Combined	PFAs	Less Than
5/15/2014	ND	ND	ND		0.070 (Combined)
11/19/2014	ND	ND	ND		0.070 (Combined)
5/26/2016	ND	ND	ND	ND	0.070 (Combined)
4/26/2017	ND	ND	ND		0.070 (Combined)
5/30/2017	ND	ND	ND		0.070 (Combined)
6/22/2017	ND	ND	ND		0.070 (Combined)
7/21/2017	ND	ND	ND		0.070 (Combined)
8/28/2017	ND	ND	ND		0.070 (Combined)
9/22/2017	ND	ND	ND		0.070 (Combined)
10/27/2017	ND	ND	ND		0.070 (Combined)
11/27/2017	ND	ND	ND		0.070 (Combined)
12/20/2017	ND	ND	ND		0.070 (Combined)
1/25/2018	ND	ND	ND		0.070 (Combined)
2/23/2018	ND	ND	ND		0.070 (Combined)
4/17/2018	ND	ND	ND		0.070 (Combined)
5/18/2018	0.0026	ND	0.0026		0.070 (Combined)
6/20/2018	ND	ND	ND		0.070 (Combined)
7/11/2018	0.002	ND	0.002		0.070 (Combined)
5/22/2020	0.0026	0.0021	0.0047	0.0041	0.070 (Combined)
8/19/2020	0.0025	ND	0.0025	0.0060	0.070 (Combined)
11/30/2020	0.0031	0.002	0.0051	0.0093	0.070 (Combined)

## PFOS/PFOA Summary for 20B Raw

Results are listed in µg/L

Well Reg.	#	55-611717			EPA
Sample Date	20B Raw			Target	
	PFOS	PFOA	Combined	Less Than	
5/6/2014	ND	ND	ND	0.070 (Combined)	
11/5/2014	ND	ND	ND	0.070 (Combined)	
11/16/2016	ND	ND	ND	0.070 (Combined)	
7/21/2017	ND	ND	ND	0.070 (Combined)	
8/28/2017	ND	ND	ND	0.070 (Combined)	
9/22/2017	ND	ND	ND	0.070 (Combined)	
10/27/2017	ND	ND	ND	0.070 (Combined)	
11/27/2017	ND	ND	ND	0.070 (Combined)	
6/20/2018	ND	ND	ND	0.070 (Combined)	
7/11/2018	ND	ND	ND	0.070 (Combined)	
6/23/2020	ND	ND	ND	0.070 (Combined)	
8/19/2020	ND	ND	ND	0.070 (Combined)	
11/30/2020	ND	ND	ND	0.070 (Combined)	

## PFOS/PFOA Summary for Airline Reservoir

Results are listed in µg/L

Sample Date	Sample Point					EPA	% of EPA Guideline
		PFOS	PFOA	Combined	Other PFAs	Target Less Than	
5/26/2016	ALR Influent	0.019	0.0096	0.0286	0.0141	0.070 (Combined)	41%
5/26/2016	ALR Post Treatment	0.019	0.0093	0.0283	0.0135	0.070 (Combined)	40%
5/26/2016	EPDS 003 (ALR)	0.019	0.0094	0.0284	0.0135	0.070 (Combined)	41%
4/26/2017	EPDS 003 (ALR)	0.014	0.0075	0.0215		0.070 (Combined)	31%
5/30/2017	EPDS 003	0.0087	0.0051	0.0138		0.070 (Combined)	20%
6/22/2017	EPDS 003	0.0093	0.0029	0.0122		0.070 (Combined)	17%
7/21/2017	EPDS 003	0.0085	0.0057	0.0142		0.070 (Combined)	20%
8/28/2017	EPDS 003	0.0071	0.0046	0.0117		0.070 (Combined)	17%
10/27/2017	EPDS 003 (ALR)	ND	ND	ND		0.070 (Combined)	
11/27/2017	EPDS 003 (ALR)	ND	0.0026	0.0026		0.070 (Combined)	4%
12/20/2017	EPDS 003 (ALR)	ND	0.0031	0.0031		0.070 (Combined)	4%
1/25/2018	EPDS 003 (ALR)	0.011	0.0099	0.0209		0.070 (Combined)	30%
2/23/2018	EPDS 003 (ALR)	0.016	0.012	0.028		0.070 (Combined)	40%
3/23/2018	EPDS 003 (ALR)	0.0046	0.0078	0.0124		0.070 (Combined)	18%
4/17/2018	EPDS 003 (ALR)	0.0092	0.0087	0.0179		0.070 (Combined)	26%
5/18/2018	EPDS 003 (ALR)	0.011	0.01	0.021		0.070 (Combined)	30%
6/20/2018	EPDS 003 (ALR)	0.012	0.01	0.022		0.070 (Combined)	31%
7/11/2018	EPDS 003 (ALR)	0.015	0.012	0.027		0.070 (Combined)	39%
1/27/2021	EPDS 003 (ALR)	0.0049	0.0076	0.0125	0.0237	0.070 (Combined)	18%
2/26/2021	EPDS 003 (ALR)	0.0075	0.0098	0.0173	0.0283	0.070 (Combined)	25%

## PFOS/PFOA Summary for Townwell Reservoir

Results are listed in µg/L

Sample Date	Sample Point					EPA	% of EPA Guideline
		PFOS	PFOA	Combined	Other PFAs	Target Less Than	
5/26/2016	TWR Influent	ND	ND	ND	0.0034	0.070 (Combined)	
5/26/2016	TWR Post Treatment	ND	ND	ND	0.0032	0.070 (Combined)	
5/26/2016	EPDS 001 (TWR)	ND	0.0029	0.0029	0.0042	0.070 (Combined)	4%
4/26/2017	EPDS 001	ND	0.0026	0.0026		0.070 (Combined)	4%
5/30/2017	EPDS 001	ND	0.003	0.003		0.070 (Combined)	4%
6/22/2017	EPDS 001	ND	0.0029	0.0029		0.070 (Combined)	4%
7/21/2017	EPDS 001	ND	0.0028	0.0028		0.070 (Combined)	4%
8/28/2017	EPDS 001	ND	0.0027	0.0027		0.070 (Combined)	4%
10/27/2017	EPDS 001 (TWR)	ND	0.0025	0.0025		0.070 (Combined)	4%
11/27/2017	EPDS 001 (TWR)	ND	0.0028	0.0028		0.070 (Combined)	4%
12/20/2017	EPDS 001 (TWR)	ND	ND	ND		0.070 (Combined)	
1/25/2018	EPDS 001 (TWR)	ND	0.0026	0.0026		0.070 (Combined)	4%
2/23/2018	EPDS 001 (TWR)	ND	ND	ND		0.070 (Combined)	
3/23/2018	EPDS 001 (TWR)	ND	0.0032	0.0032		0.070 (Combined)	5%
4/17/2018	EPDS 001 (TWR)	ND	0.0037	0.0037		0.070 (Combined)	5%
5/18/2018	EPDS 001 (TWR)	ND	0.0032	0.0032		0.070 (Combined)	5%
6/20/2018	EPDS 001 (TWR)	ND	0.0034	0.0034		0.070 (Combined)	5%
7/11/2018	EPDS 001 (TWR)	ND	0.0038	0.0038		0.070 (Combined)	5%
2/26/2021	TWR	0.0021	0.0043	0.0064	0.0123	0.070 (Combined)	9%

PFOS/PFOA Summary for Points in the Distribution System

Results are listed in µg/L

Sample Date	Sample Point	PFOS	PFOA	Combined	Other PFAs	EPA	% of EPA
						Target Less Than	Guideline
5/26/2016	Goodyear West Interconnect	ND	0.0036	0.0036	0.0062	0.070 (Combined)	5%
5/26/2016	Dysart & Roosevelt Canal	0.0130	0.0041	0.0171	0.0107	0.070 (Combined)	24%
	El Mirage & Keim	0.0200	0.0100	0.0300	0.0152	0.070 (Combined)	43%
	El Mirage at Mine Entrance	0.0170	0.0085	0.0255	0.0121	0.070 (Combined)	36%
	Litchfield & Peck	0.0200	0.0096	0.0296	0.0136	0.070 (Combined)	42%
	McDowell & 136th Drive	ND	ND	ND	ND	0.070 (Combined)	
	McDowell & 303	ND	0.0025	0.0025	0.0039	0.070 (Combined)	4%
	Peck W/of 135th Ave	0.0190	0.0092	0.0282	0.0135	0.070 (Combined)	40%
	Sarival & Charles	ND	0.0031	0.0031	0.0045	0.070 (Combined)	4%
10/9/2017	SS-10 (Near Thomas & Litchfield)	ND	ND	ND		0.070 (Combined)	
	SS-28 (Near Bethany Home & Litchfield)	0.0077	0.005	0.0127		0.070 (Combined)	18%
	SS-50 (Near Indian School & Sarival)	ND	0.0032	0.0032		0.070 (Combined)	5%
1/25/2018	D10 (Near Thomas & Litchfield)	ND	0.0026	0.0026		0.070 (Combined)	4%
	D22 (Near McDowell & Bullard)	ND	0.0028	0.0028		0.070 (Combined)	4%
	D25 (Near McDowell & Sarival)	0.0096	0.0077	0.0173		0.070 (Combined)	25%
	D28 (Near Bethany Home & Litchfield)	0.011	0.0092	0.0202		0.070 (Combined)	29%
	D40 (Near Camelback & El Mirage)	ND	0.0026	0.0026		0.070 (Combined)	4%
	D44 (Near Camelback & Litchfield)	0.0044	0.0037	0.0081		0.070 (Combined)	12%
	D50 (Near Indian School & Sarival)	0.0088	0.0075	0.0163		0.070 (Combined)	23%
	DLUKE (Near Bethany Home & Litchfield)	0.011	0.0089	0.0199		0.070 (Combined)	28%
D303 (Near Indian School & Cotton)	0.0092	0.008	0.0172		0.070 (Combined)	25%	
8/6/2018	SS# 18 (Near Bethany Home & El Mirage)	0.015	0.012	0.027		0.070 (Combined)	39%
2/22/2019	SS #28 (Near Bethany Home & Litchfield)	0.0026	0.004	0.0066		0.070 (Combined)	9%
	SS #39 (Near Camelback & El Mirage)	0.0027	0.0042	0.0069		0.070 (Combined)	10%
3/4/2019	SS #39 (Near Camelback & El Mirage)	0.0033	0.0041	0.0074		0.070 (Combined)	11%
	SS #28 (Near Bethany Home & Litchfield)	0.003	0.004	0.007		0.070 (Combined)	10%
	SS #44 (Near Camelback & Litchfield)	0.0025	0.0038	0.0063		0.070 (Combined)	9%
	SS #12 (Near Indian School & Falcon)	0.0036	0.0041	0.0077		0.070 (Combined)	11%
	SS #20 (Near Thomas Algnmnt & Sarival)	0.0035	0.004	0.0075		0.070 (Combined)	11%
	SS #08 (Near McDowell & Sarival)	0.0036	0.0041	0.0077		0.070 (Combined)	11%
	SS #37 (Near McDowell & Bullard)	ND	0.0044	0.0044		0.070 (Combined)	6%
2/26/2021	SS-36 (South of Valley Interconnect)	0.0073	0.0099	0.0172	0.0288	0.070 (Combined)	25%