

## **ADEQ Water Quality Report Analysis**

### **2024 Q2 - April 1 - June 30**

- During quarter 2, there were no exceedances of permit limits observed in the samples collected from the outflow pipe of the mine shaft sump. Sump water continues to be stored and evaporated at the lined on-site non-stormwater pond.
- The mine shaft pump operated for 88 of 91 days in the quarter averaging 13.25 thousand gallons per day.
- ADEQ performed an inspection on May 16, 2024, and found the facility to be in compliance.